



STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

PO Box 176 Jefferson City, MO 65102-0176

Environmental Services Program
RESULTS OF SAMPLE ANALYSES FOR PUBLIC WATER SUPPLIES

JIM GALVIN
BIG COUNTRY ACRES SUBDIVISION
1657 LILY MARIE LANE

Order ID 121216396



WENTZVILLE MO 63385

PWS County: ST CHARLES

Report Date: 01/25/2013

PWS ID: MO6030662

BIG COUNTRY ACRES SUBDIVISION



Sample Number: AB89477

Date Collected: 01/07/2013 Sample Location: WELL # 1 - 19 MADRE CT WL 13384

Comments

Analysis Performed	Result	MCL	Units
Nitrate + Nitrite as N	Nitrate + Nitrite as N	<0.01	10 mg/L

MCL- A Maximum Contaminant Level (MCL) is the legal threshold limit on the amount of a substance that is allowed in drinking water under the Federal Safe Drinking Water Act. MCLs are health based, legally enforceable standards. Drinking water results below the MCLs are considered safe. "*" denotes an Action Level.

SS- Secondary Drinking Water Regulations (secondary standards) are non-enforceable guidelines regulating contaminants that may cause aesthetic effects in drinking water, such as taste, color or odor. It is recommended that water systems comply with secondary standards but water systems are not required to comply.

The analysis of this sample was performed in accordance with procedures approved or recognized by the U.S Environmental Protection Agency. If you have any questions, please contact Mr. Todd Eichholz at 573/751-4090.

Chris Boldt

Chris Boldt, Laboratory Manager
Environmental Services Program
Division of Environmental Quality